

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 103

Dated: 16/06/2025

It is certified that an inspection team headed by Mr. Vipin Katara from E.E. PHED, PROJECT, DIV - I, JAIPUR PHED inspected the MY OWN SCHOOL, RAM MARG, SHYAM NAGAR, AJMER ROAD, JAIPUR-302019 on 22-05-2025 and on the basis of Water Test Report (Attached) bearing No. : Lab/Sup.Chem. (HM) / Jaipur (City)/2025-2026/743 Dated 28-05-2025 of OFFICE OF THE CHIEF CHEMIST, PHED Laboratory, Gandhi Nagar, Jaipur (PHED Lab) certified that the MY OWN SCHOOL, RAM MARG, SHYAM NAGAR, AJMER ROAD, JAIPUR-302019 has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 27-05-2026

Signature with Seal:

Name : Mr. Vipin Katara

Designation : Assistant Engineer

Name & Address of the Office / Department : PHED, DIV-I, Jaipur

To

MY OWN SCHOOL

RAM MARG, SHYAM NAGAR,

AJMER ROAD, JAIPUR - 302019

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

OFFICE OF THE CHIEF CHEMIST

PUBLIC HEALTH ENGINEERING DEPARTMENT LABORATORY, GANDHI NAGAR, JAIPUR

REPORT OF THE CHEMICAL EXAMINATION OF WATER

No: Lab/Sup.Chem. (HM) / Jaipur (City) /2025-2026/ 743

Date: 28/5/25

To,
My Own School,
Shyam Nagar,
Jaipur.

The Sample was not Collected
by this Laboratory

Not Valid for water
quality ! Legal Cases

Date of Receipt-26.05.25

Particulars			RO Water My Own School
	value as per I.S.:10500/2012		
Village / Town	Requirement (Acceptable Limit)	Permissible Limit in the absence of Alternate Source	Jaipur
Date of Collection			26.05.2025
Lab. Sample No.			P-41
1. pH	6.5-8.5	6.5-8.5	6.82
2. Turbidity (NTU)	1	5	Nil
3. Colour (Hazen units)	5	15	None
4. Odour	Un Objectionable		U.O
5. Total Alkalinity(as CaCo3) mg/l	200	600	30
6. Total Hardness (as CaCo3) mg/l	200	600	40
7. Calcium (as Ca) mg/l	75	200	8
8. Magnesium (as Mg) mg/l	30	100	5
9. Chloride (as Cl-) mg/l	250	1000	40
10. Nitrates (as NO3-) mg/l	45	45	4
11.Sulphate(as So4- 2)mg/l	200	400	4
12. Total Dissolved Solids mg/l	500	2000	165
13.Fluoride mg/l	1.00	1.5	0.03
14.Iron mg/l	1.0	No Relaxation	Nil
15.Arsenic mg/l	0.01	No Relaxation	Nil

Remark- 1. All chemical parameters except pH are in mg/l
2. Tested Results Relate only to The Samples send by you

28/05/25
Superintending Chemist (Heavy Metal)
P.H.E.D. Laboratory, Jaipur

No: Lab/ Sup.Chem. (HM) / Jaipur (City) /2025-2026/
Copy to:- 1.The Chief Chemist, PHED Raj. Jaipur

Date:

Superintending Chemist (Heavy Metal)
P.H.E.D. Laboratory, Jaipur